

DECLARATION OF PERFORMANCE  
(EU) 305/2011

DoP N° : DC00001

1. Identification code of the product type          Controlled door closing devices
2. Type number    MAB 4232    EN3 Floorspring
3. Intended use    On fire and smoke compartmentation doors
4. Manufacturer    ASSA ABLOY Italia S.p.A.  
via Bovaresa,13  
40017- San Giovanni in Persiceto (BOLOGNA) ITALY
5. System of assessment and verification of constancy of performance    System 1

## 6. The construction product is covered by a harmonised standard

Notified Body – N. 0425	Harmonised Standard	CE Certificate / Certification Date
ICIM S.p.a. – Piazza Don Mapelli,75 -20099 SESTO SAN GIOVANNI (MI) - ITALY	EN1154:1996 + A1:2002 +AC:2006	0425-CPR-000524 21/03/2017

## 7. Declared Performance:

Classification acc. to EN1154:1996 + A1:2002 + AC:2006

<b>4232</b>	3	8	3	1	1	4
-------------	---	---	---	---	---	---

Essential Characteristics	Performance	Harmonised Technical Specification
<b>Self-closing</b>		
5.2.1. General		EN1154:1996 + A1:2002 + AC:2006
5.2.3. Closing moment	Value > Table 1	
5.2.4 Opening moment	Value > Table 1	
5.2.5 Efficiency	Value > Table 1	
5.2.6 Closing time	T<3s or T>20s. Variation OK after 500.000 cycles	

ASSA ABLOY Italia S.p.A.  
Sede legale / Legal address:Via Bovaresa 13  
40017 San Giovanni in  
Persiceto (BO) Italy  
Tel. +39 051 6812411  
Fax. +39 051 827486  
www.assaabloy.itCap. Soc.:Euro 6.500.000 i.v.  
C.F./Reg. Imp.: 02275750590  
P.I./VAT: IT 02275750590  
R.E.A.: 1176693/RM  
assaabloyitaliapec@legalmail.it  
info@assaabloy.itSede di Roma  
Rome UnitVia Paolo di Dono, 149  
00142 Roma (RM) Italy  
Tel. +39 051 6812411  
Fax. +39 051 827486Sede di Milano  
Milan UnitVia Concordia 16  
20838 Renate  
(MB) Italy  
Tel. +39 0362 982271  
Fax. +39 0362 982235Sede di Piacenza  
Piacenza UnitVia Leonardo Da Vinci, 1/3  
29016 - Cortemaggiore  
(PC) Italy  
Tel. +39 0523 255511  
Fax. +39 0523 835191Sede di Treviso  
Treviso UnitVia San Pio X, 52/A  
31020 San Vendemiano  
(TV) Italy  
Tel. +39 0438 912275  
Fax. +39 0438 912255

5.2.7 Angles of operation	Grade 3: for closing doors from at least 105° open (≤175°)	
5.2.8 Overload performance	Withstands the closing overload tests	
5.2.9 Temperature dependence	Closing time (from 90° opening position) at 40°C and -15°C: ≥3s and ≤25s	
5.2.10 Fluid leakage	None throughout the test	
5.2.11 Damage	None throughout the test	
5.2.12 Latch Control	Variable between 15° - 0°	
5.2.13 Backcheck	NPD	
5.2.14 Delayed closing	NPD	
5.2.15 Closing force	EN3	
5.2.16 Zero position	0 cycles: ≤ 3 mm; 500.000 cycles: ≤ 6 mm	
5.2.18 Fire/Smoke door suitability	Grade 1: suitable for use on fire/smoke doors (≥EN3)	
<b>Durability of self-closing</b>		
5.2.2. Durability	Grade 8: 500.000 test cycles	
5.2.17.1 Corrosion resistance	Grade 4: very high resistance (240h)	
5.2.17.2 Corrosion resistance	The closing moment is >80% of the value measured prior to the salt spray test	
<b>Dangerous Substances</b>	The materials used in this product do not contain or release any dangerous substances in excess of the maximum levels specified in existing European material standards or any national regulation	

#### 8. Declaration of Performance:

The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 7. This declaration of performance is issued under the sole responsibility of the manufacturer.

Maddalena Marchesini (Managing Director - ASSA ABLOY Italia S.p.A.)



S. Giovanni In Persiceto – Bologna (Italy)-21/03/2017

#### ASSA ABLOY Italia S.p.A.

Sede legale / Legal address:

Via Bovaresa 13  
40017 San Giovanni in  
Persiceto (BO) Italy  
Tel. +39 051 6812411  
Fax. +39 051 827486  
www.assaabloy.it

Cap. Soc.: Euro 6.500.000 i.v.  
C.F./Reg. Imp.: 02275750590  
P.I./VAT: IT 02275750590  
R.E.A.: 1176693/RM  
assaabloyitaliapec@legalmail.it  
info@assaabloy.it

#### Sede di Roma Rome Unit

Via Paolo di Dono, 149  
00142 Roma (RM) Italy  
Tel. +39 051 6812411  
Fax. +39 051 827486

#### Sede di Milano Milan Unit

Via Concordia 16  
20838 Renate  
(MB) Italy  
Tel. +39 0362 982271  
Fax. +39 0362 982235

#### Sede di Piacenza Piacenza Unit

Via Leonardo Da Vinci, 1/3  
29016 - Cortemaggiore  
(PC) Italy  
Tel. +39 0523 255511  
Fax. +39 0523 835191

#### Sede di Treviso Treviso Unit

Via San Pio X, 52/A  
31020 San Vendemiano  
(TV) Italy  
Tel. +39 0438 912275  
Fax. +39 0438 912255